

# DGUV V3

Feuerwehr: ALTENSITTENBACH



Geschirrmobil / LAU-FA 265 / TÜV 04/26

Datum: 16.04.2025

Seite: \_\_\_\_\_

|    | Prüfling:              | S-Art: | Sichtprüf. | R - PE |        | R - ISO |        | IEA     |        | N. s. T. |        | IB EDV  |        | Funktion: |
|----|------------------------|--------|------------|--------|--------|---------|--------|---------|--------|----------|--------|---------|--------|-----------|
|    |                        |        |            | i.O.   | Fehler | i.O.    | Fehler | i.O.    | Fehler | i.O.     | Fehler | i.O.    | Fehler |           |
| 1  | KS5 25 400V/230V / Fi  | I      | i.O.       | ≥ 0,5Ω |        | ≥ 1,0MΩ |        | ≤ 1,0mA |        | X        |        | < 0,5mA |        | Fi > i.O. |
| 2  | Geschirrspüler         | I      | i.O.       | ≥ 0,5Ω |        | ≥ 1,0MΩ |        | ≤ 1,0mA |        | X        |        | < 0,5mA |        |           |
| 3  | V.3m 400V              | I      | i.O.       | ≥ 0,5Ω |        | ≥ 1,0MΩ |        | ≤ 1,0mA |        | X        |        | < 0,5mA |        |           |
| 4  | Beleuchtung Ladefläche | II     | i.O.       |        |        | ≥ 1,0MΩ |        | ≤ 0,5mA |        | X        |        | < 0,5mA |        |           |
| 5  |                        |        |            |        |        |         |        |         |        |          |        |         |        |           |
| 6  |                        |        |            |        |        |         |        |         |        |          |        |         |        |           |
| 7  |                        |        |            |        |        |         |        |         |        |          |        |         |        |           |
| 8  |                        |        |            |        |        |         |        |         |        |          |        |         |        |           |
| 9  |                        |        |            |        |        |         |        |         |        |          |        |         |        |           |
| 10 |                        |        |            |        |        |         |        |         |        |          |        |         |        |           |
| 11 |                        |        |            |        |        |         |        |         |        |          |        |         |        |           |
| 12 |                        |        |            |        |        |         |        |         |        |          |        |         |        |           |
| 13 |                        |        |            |        |        |         |        |         |        |          |        |         |        |           |
| 14 |                        |        |            |        |        |         |        |         |        |          |        |         |        |           |

Prüfer: Bundil Norbert, Hauptamtlicher Gerätewart FF-Hersbruck

